Sl. No.	Name of the project proponent/State	Installed capacity (MW)	Date of receipt of DPR in CEA
11.	Vembar CCGT (M/s India Power Projects Ltd.) Tamil Nadu	2000	2/97
12.	Pithampur DG Plant (M/s Shapoorji Pallonji Power Co. Ltd.), Madhya Pradesh	120	2/97
13.	Raigarh TPS (M/s Jindal Power Ltd.) Madhya Pradesh	550	2/97
14.	Vemagiri CCPP (M/s Ispat Industries Ltd.) Andhra Pradesh	468	2/97

Capacity of Dabhol Power Project

2026. SHRI DIPANKER MUKHERJEE:
SHRI NILOTPAL BASU:

Will the PRIME MINISTER be pleased to refer to answer to Unstarred Question 2980 given in the Rajya Sabha on the 19th December, 1996 and state:

(a) the original ISO capacity of Dabhol Power Project;

(b) whether the capacity was specified for site condition;

(c) the permissible auxiliary consumption as per CEA norms; and

(d) the auxiliary consumption of original and renegotiated project?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (DR. S. VENUGOPALACHARI): (a) and (b) The original gross capacity of Dabhol Power Project as indicated by M/s. Dabhol Power Company Ltd. was 2249 MW at ISO condition. As against this, the net capacity at site was indicated as 2015 MW.

(c) The permissible auxiliary consumption as per CEA norms and also specified in the tariff notification dated 30.2.1992 is 3% for combined cycle power plants based on gas and naphtha.

(d) the auxiliary power consumption of original and renegotiated Dabhol TPP works out to about 2% after adjustment in deration of capacity at the site conditions.

Frequency Fluctuation in Different Grids

2027. SHRI DIPANKAR MUKHERJEE:
SHRI NILOTPAL BASU:

Will the PRIME MINISTER be pleased to state:

(a) the average percentage of time of the day during which the frequency remained above 50.5 HZ during 1995-96 and 1996-97, till December, 1996 in North, South, West and East Zone Grids;

(b) the energy lost on this account;

(c) the average percentage of time of the dav when frequency remained healthy i.e. 48.5 HZ to 50 HZ during 1994-95, 1995-96 and 1996-97 till December, 1996; and

(d) the average annual O & M expenditure of RLDCs during the same period?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (DR. S. VENUGOPALACHARI): (a) The average percentage of the time of the day during